

We use some essential cookies to make this service work.

We'd also like to use analytics cookies so we can understand how you use the service and make improvements.

[Accept analytics cookies](#)
[Reject analytics cookies](#)
[View cookies](#)

# Energy performance certificate (EPC)

## Certificate contents

- Rules on letting this property
- Energy rating and score
- Breakdown of property's energy performance
- How this affects your energy bills
- Impact on the environment
- Changes you could make
- Who to contact about this certificate
- Other certificates for this property

## Share this certificate

- Email
- Copy link to clipboard
- Print

|  |  |  |
|--|--|--|
| Coombe Villa<br>12 Coombe Road<br>Dartmouth<br>TQ6 9PQ |  | Energy rating<br> |
| Valid until<br>17 February 2034                        | Certificate number<br>9064-3007-4202-2174-3200 |  |

|                  |                   |
|------------------|-------------------|
| Property type    | End-terrace house |
| Total floor area | 211 square metres |

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](#).

## Energy rating and score

This property's energy rating is E. It has the potential to be D.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                     | Rating    |
|----------------------|---|-----------|
| Wall                 | System built, as built, no insulation (assumed) | Very poor |
| Wall                 | Solid brick, as built, no insulation (assumed)  | Poor      |
| Wall                 | Cavity wall, as built, insulated (assumed)      | Good      |
| Roof                 | Pitched, no insulation                          | Very poor |
| Roof                 | Pitched, insulated (assumed)                    | Average   |
| Window               | Partial double glazing                          | Poor      |
| Main heating         | Boiler and radiators, mains gas                 | Good      |
| Main heating control | Programmer, room thermostat and TRVs            | Good      |
| Hot water            | From main system                                | Good      |
| Lighting             | Low energy lighting in 52% of fixed outlets     | Good      |
| Floor                | Suspended, no insulation (assumed)              | N/A       |
| Floor                | Solid, no insulation (assumed)                  | N/A       |
| Secondary heating    | Room heaters, mains gas                         | N/A       |

### Primary energy use

The primary energy use for this property per year is 321 kilowatt hours per square metre (kWh/m<sup>2</sup>).

[About primary energy use](#)

### Additional information

Additional information about this property:

- System build present
- Dwelling may be exposed to wind-driven rain

## How this affects your energy bills

An average household would need to spend **£4,449 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,343 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 32,683 kWh per year for heating
- 3,192 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

### Carbon emissions

|                                      |                                |
|--------------------------------------|--------------------------------|
| An average household produces        | 6 tonnes of CO <sub>2</sub>    |
| This property produces               | 12.0 tonnes of CO <sub>2</sub> |
| This property's potential production | 7.2 tonnes of CO <sub>2</sub>  |

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

[Do I need to follow these steps in order?](#)

### Step 1: Increase loft insulation to 270 mm

|  |             |
|--|-------------|
| Typical installation cost                | £100 - £350 |
| Typical yearly saving                    | £568        |
| Potential rating after completing step 1 | 51 E        |

### Step 2: Internal or external wall insulation

|   |                  |
|---|------------------|
| Typical installation cost                       | £4,000 - £14,000 |
| Typical yearly saving                           | £144             |
| Potential rating after completing steps 1 and 2 | 53 E             |

### Step 3: Floor insulation (suspended floor)

|  |               |
|--|---------------|
| Typical installation cost                      | £800 - £1,200 |
| Typical yearly saving                          | £174          |
| Potential rating after completing steps 1 to 3 | 55 D          |

### Step 4: Draught proofing

|  |            |
|--|------------|
| Typical installation cost                      | £80 - £120 |
| Typical yearly saving                          | £124       |
| Potential rating after completing steps 1 to 4 | 56 D       |

### Step 5: Low energy lighting

|  |      |
|--|------|
| Typical installation cost                      | £60  |
| Typical yearly saving                          | £77  |
| Potential rating after completing steps 1 to 5 | 57 D |

### Step 6: Solar water heating

|  |                 |
|--|-----------------|
| Typical installation cost                      | £4,000 - £6,000 |
| Typical yearly saving                          | £102            |
| Potential rating after completing steps 1 to 6 | 58 D            |

### Step 7: Double glazed windows

Replace single glazed windows with low-E double glazed windows

|  |                 |
|--|-----------------|
| Typical installation cost                      | £3,300 - £6,500 |
| Typical yearly saving                          | £154            |
| Potential rating after completing steps 1 to 7 | 60 D            |

### Step 8: Solar photovoltaic panels, 2.5 kWp

|  |                 |
|--|-----------------|
| Typical installation cost                      | £3,500 - £5,500 |
| Typical yearly saving                          | £633            |
| Potential rating after completing steps 1 to 8 | 65 D            |

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](#). This will help you buy a more efficient, low carbon heating system for this property.

### More ways to save energy

[Find ways to save energy in your home](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |  |
|-----------------|--|
| Assessor's name | Richard Stevens  |
| Telephone       | 07909923555  |
| Email           | <a href="mailto:richyrich2001@gmail.com">richyrich2001@gmail.com</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |  |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd  |
| Assessor's ID        | EES/024978   |
| Telephone            | 01455 883 250  |
| Email                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

### About this assessment

|                        |  |
|------------------------|--|
| Assessor's declaration | Employed by the professional dealing with the property transaction |
| Date of assessment     | 16 February 2024   |
| Date of certificate    | 18 February 2024   |
| Type of assessment     | <a href="#">RdSAP</a>  |

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.